

HARRIS COUNTY M.U.D. No. 465

PWS ID # 1013674

2022 Annual Drinking Water Quality Report

Phone No: 281-350-0895

This is your water quality report for January 1, 2022 to December 31, 2022

En Español

Este reporte incluye informacion importante sobre el agua para tomar. Para asistencia en espanol, por favor llame al telefono 281-350-0895.

OUR DRINKING WATER IS SAFE

This report is a summary of the quality of the water we provide to our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (USEPA) required tests and is presented in the following tables. We hope this information helps you become more knowledgeable about your drinking water.

Public Participation Opportunities concerning your water system may be made at regularly scheduled meetings on the Third Tuesday of each month at 12:30 pm, Coats Rose, P.C., 9 Greenway Plaza, Suite 1000, Houston, Texas 77046. You may contact Tarynn Fossati at TNG Utility Corp., phone # 281-350-0895, with any questions or concerns you may have.

Where do we get your drinking water?

Our drinking water is obtained from groundwater sources. It comes from water-bearing sands known as the Evangeline Aquifer.

No Source Water Assessment for your drinking water sources has been conducted by the Texas Commission on Environmental Quality for your water system. The report describes the susceptibility and the types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information in this assessment allows us to focus our source water protection strategies.

Water Sources: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: (i) microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; (ii) inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (iii) pesticides and herbicides, which might have a variety of sources such as agriculture, urban storm water runoff, and residential uses; (iv) organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and (v) radioactive contaminants,

which can be naturally-occurring or the result of oil and gas production and mining activities.

A Special Notice for the ELDERLY, INFANTS, CANCER PATIENTS, people with HIV/AIDS or other immune Problems: You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or Immuno-compromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791). Also, see EPA website: www.epa.gov/safewater and NRDC website: www.nrdc.org/water

All Drinking Water may Contain Contaminants

When drinking water meets federal standards there may not be any health based benefits to purchasing bottled water or point of use devices.

Drinking water, *including bottled water*, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at (800-426-4791).

In order to ensure that the tap water is safe to drink, the USEPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

PWS ID # 1013674



THE NEXT GENERATION OF
WATER AND WASTEWATER UTILITY SERVICES

About the Following Table

The following table contains all of the federally regulated or monitored chemical constituents which have been found in your drinking water. USEPA requires water systems to test up to 97 constituents. The data presented in the report is from the most recent testing done in accordance with the regulations.

Abbreviations and Definitions

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Maximum Contaminant Level Goal (MCLG) - The level of contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Residual Disinfectant Level (MRDL) - The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of use of disinfectants to control microbial contamination.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

MFL: million fibers per liter (a measure of asbestos)

ppm - milligrams per liter or parts per million-or one ounce in 7,350 gallons of water.

ppb - micrograms per liter or parts per billion-or one ounce in 7,350,000 gallons of water.

pCi/l - pico curies per liter (a measure of radioactivity)

N/A - not applicable

mrem - millirems per year (a measure of radiation absorbed by the body)

NTU-nephelometric turbidity units (a measure of turbidity)

ppt- parts per trillion, or nanograms per liter (ng/L)

ppq- parts per quadrillion, or picograms per liter (pg/L)

Harris County M.U.D. No. 465 - 2022 Drinking Water Quality Report Data

| Disinfectant type and unit of measure | Year Sampled | Average Level | Minimum Level | Maximum Level | MRDL | MRDLG | Units | Violation | Likely Source of Contamination |
|---------------------------------------|--------------|---------------|---------------|---------------|------|-------|-------|-----------|--|
| Chlorine Residual, Free | 2022 | 1.56 | 1.05 | 2.07 | 4.00 | 4.00 | ppm | No | Water additive used to control microbes. |

Total Coliform: MONTHLY TESTS FOUND NO COLIFORM BACTERIA

Organics: TESTING WAIVED, NOT REPORTED, OR NONE DETECTED

Fecal Coliform: MONTHLY TESTS FOUND NO FECAL COLIFORM BACTERIA

Turbidity: NOT REQUIRED

TNG Utility Corp.
P.O. Box 2749
Spring, TX 77383



2020 Drinking Water Quality Report Enclosed

PRESORTED
STANDARD
US POSTAGE
PAID
SPRING, TX
PERMIT #176