

Pinehurst Decker Prairie WSC

2022 Annual Drinking Water Quality Report

PWS ID # 1700507

This is your water quality report from January 1, 2022 to December 31, 2022.

Phone No: 281-350-0895

En Español

Este reporte incluye informacion importante sobre el agua para tomar. Para asistencia en espanol, por favor llame al telefono 281-350-0895.

OUR DRINKING WATER IS SAFE

This report is a summary of the quality of the water we provide to our customers. The analysis was made by using the data from the most recent Environmental Protection Agency (EPA) required tests and is presented in the following tables. We hope this information helps you become more knowledgeable about your drinking water.

Where do we get your drinking water?

Public Participation Opportunities concerning your water system may be made at regularly scheduled meetings on the second Monday of each month at 7:00 p.m., 32434 Decker Prairie Rd., Magnolia, Tx 77335 or you may contact Tarynn Fossati at TNG Utility Corporation., phone #281-350-0895, with any questions or concerns you may have.

Our drinking water is obtained from Groundwater sources. It comes from the GULF COAST AQUIFERS. These water-bearing sands consist of the Chico and Evangeline Aquifers. Generally most Groundwater is protected from microbial contaminants, including *Cryptosporidium*.

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confident Report. For more information on source water assessments and protection efforts at our system, contact Tarynn Fossati at 281-350-0895.

Water Sources: Other sources of drinking water (both tap water and bottled water) can include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: (i) microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; (ii) inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (iii) pesticides and herbicides, which might have a variety of sources such as agriculture, urban storm water runoff, and residential uses; (iv) organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and

petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and (v) radioactive contaminants, which can be naturally-occurring or the result of oil and gas production and mining activities.

A Special Notice for the ELDERLY, INFANTS, CANCER PATIENTS, people with HIV/AIDS or other immune Problems:

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or Immuno-compromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

EPA website: www.epa.gov/safewater

NRDC website: www.nrdc.org/water

All Drinking Water may Contain Contaminants

When drinking water meets federal standards there may not be any health based benefits to purchasing bottled water or point of use devices.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800-426-4791).

In order to ensure that the tap water is safe to drink, the EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact TNG Utility.



TNG UTILITY CORP.

THE NEXT GENERATION OF
WATER AND WASTEWATER UTILITY SERVICES

About the Following Table

The following table contains all of the federally regulated or monitored chemical constituents which have been found in your drinking water. USEPA requires water systems to test up to 97 constituents. The data presented in the report is from the most recent testing done in accordance with the regulations.

Abbreviations and Definitions

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Maximum Contaminant Level Goal (MCLG) - The level of contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Residual Disinfectant Level (MRDL) - The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of use of disinfectants to control microbial contamination.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

MFL: million fibers per liter (a measure of asbestos)

ppm - milligrams per liter or parts per million-or one ounce in 7,350 gallons of water.

ppb - micrograms per liter or parts per billion-or one ounce in 7,350,000 gallons of water.

pCi/l - pico curies per liter (a measure of radioactivity)

N/A - not applicable

mrem - millirems per year (a measure of radiation absorbed by the body)

NTU-nephelometric turbidity units (a measure of turbidity)

ppt- parts per trillion, or nanograms per liter (ng/L)

ppq- parts per quadrillion, or picograms per liter (pg/L)

Pinehurst Decker Prairie WSC - 2022 Drinking Water Quality Report Data

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	07/27/2021	2.7	2.7 - 2.7	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	07/27/2021	0.214	0.214 - 0.214	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	07/27/2021	0.18	0.18 - 0.18	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Selenium	07/27/2021	4.1	4.1 - 4.1	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/Photon emitters	03/09/2018	4.6	4.6 - 4.6	0	50	pCi/L*	N	Decay of natural and man-made deposits.
Gross Alpha excluding Radon and Uranium	03/09/2018	4	4 - 4	0	15	pCi/L	N	Erosion of natural deposits.

*EPA considers 50 pCi/L to be the level of concern for beta articles

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Chlorine, Free	2022	1.64	1.08 - 2.6	4	4	ppm	N	Water additive used to control microbes.

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2022	1	1.2 - 1.2	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

*The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year

Pinehurst Decker Prairie - 2022 Drinking Water Quality Report Data Continuation

Lead and Copper: - These samples are taken from the customer taps. Definitions: Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety. Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

The 90th percentile of the Lead/ Copper analysis means the top 10% (highest sample results) of all samples collected.

Lead and Copper	Date Sam-pled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	07/23/2020	1.3	1.3	0.384	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of house-hold plumbing systems.
Lead	07/23/2020	0	15	0.689	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Recommended Additional Health Information for Lead in Drinking Water:

"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in home plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested by an approved laboratory. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>."

Secondary Constituents

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not EPA. These constituents are not causes for health concerns, but may greatly affect the appearance and taste of your water. For more information contact TNG at 281-350-0895.

Total Coliform: MONTHLY TESTS FOUND NO COLIFORM BACTERIA

Organics: TESTING WAIVED, NOT REPORTED, OR NONE DETECTED

Fecal Coliform: MONTHLY TESTS FOUND NO FECAL COLIFORM BACTERIA

Turbidity: NOT REQUIRED

Secondary and Other Non-Regulated Constituents: - No associated adverse health effects with the following:

Secondary & Other Non-regulated Constituents	Collection Date	Average Level	Range of Detected Levels (low-high)	Secondary Limit	Unit of Measure	Source of Constituent
Chloride	2021	88	0-88	N/A	Ppm	Naturally occurring soluble mineral salts
Iron	2021	.221	0-0.221	.3	Ppm	Erosion of natural deposits: iron or steel water delivery equipment or facilities
Manganese	2021	0.009	0-0.009	.05	Ppm	Abundant naturally occurring element
Zinc	2021	0.04	0-0.04	5.0	Ppm	Moderately abundant naturally occurring element used in the metal industry
Total Dissolved Solids	2021	395	0-395	N/A	Ppm	Erosion of natural deposits
Sulfate	2021	14.0	0-14	300	ppm	Abundant naturally occurring element

